

BEFORE THE CORPORATION COMMISSION OF THE STATE OF OKLAHOMA

IN THE MATTER OF THE APPLICATION OF)
OKLAHOMA GAS AND ELECTRIC COMPANY)
FOR AN ORDER OF THE COMMISSION) Cause No. PUD 202000021
APPROVING A RECOVERY MECHANISM FOR)
EXPENDITURES RELATED TO THE)
OKLAHOMA GRID ENHANCEMENT PLAN)



Rebuttal Testimony

of

Kandace Smith

on behalf of

Oklahoma Gas and Electric Company

September 14, 2020

Kandace Smith
Rebuttal Testimony

I. Introduction

1 **Q. Would you please state your name and business address?**

2 A. My name is Kandace Smith. My business address is 321 North Harvey, Oklahoma City,
3 Oklahoma, 73102.

5 **Q. Are you the same Kandace Smith that previously filed direct testimony in this
6 proceeding?**

7 A. Yes.

9 **Q. What is the purpose of your Rebuttal Testimony?**

10 A. The purpose of my Rebuttal Testimony is to respond to intervenors critiques of the
11 Oklahoma Grid Enhancement Plan (“OGE Plan” or “Plan”) and its underlying analysis.

12 Specifically, I will support our cost benefit analysis by explaining why it is reasonable
13 to exclude certain revenue requirement components, as we were utilizing a project
14 optimization model not intended to calculate customer rate impacts. I will also show that
15 evaluating our plan on a circuit-by-circuit basis rather than project-by-project results in a
16 more comprehensive approach supportive of our goal to create a step-change in the way
17 we plan the system.

18 I will defend our reliability performance projections against intervenor criticism by
19 reiterating our assumptions are based on *actual* Arkansas Grid Enhancement results. I also
20 remind intervenors who criticize those projections for lack of variability that we performed
21 a sensitivity analysis on the 2020 projects and detail the results below.

22 I respond to the intervenors who claim we should ignore the full impact of outages on
23 customers despite the availability of the Department of Energy’s (DOE) Interruption Cost
24 Estimate (ICE) calculator to capture these impacts. In this section, I also address requests
25 to alter our ICE analysis and show that by using the same assumptions as were used in the
26 avoid cost of service analysis, as recommended by PUD, the Plan benefits increase to \$3.8
27 billion, an increase of \$2.4 billion in customer benefit for the Plan.

1 Finally, I discuss how our project selection criteria favored longer-term solutions as
2 opposed to shorter-term answers such a tree-trimming that will continue to occur in parallel
3 with the Plan.
4

5 **II. Background on OGE Plan**

6
7 **Q. Please summarize the OGE Plan.**

8 A. The OGE Plan is a five-year asset deployment plan is focused on upgrading aging physical
9 infrastructure while also modernizing key grid technologies. To develop the Plan, the
10 Company prioritized projects based upon a cost benefit analysis, which results in an Annual
11 Investment Plan and detailed Scope of Work for each year of the Plan. These documents
12 serve as a guide to the projects and types of work to be completed to allow for the most
13 benefit to customers, over the life of the 5-year Plan. Ultimately, the Plan will result in a
14 modernized grid that is more reliable, resilient, flexible, and efficient, while at the same
15 time maintaining affordability and enhancing service for customers.
16

17 **Q. Is the Plan focused solely on selecting projects for the purpose of improving system**
18 **reliability as measured by average reliability indices as suggested by many of the**
19 **intervenors?**

20 A. No. It is focused on modernizing and optimizing the grid through the six objectives outlined
21 in Witness Gladhill's Direct Testimony. While improved reliability and greater resilience
22 are two of the objectives, they are not the sole focus of project selection within the Plan.
23 Even when reviewing improved reliability and greater resilience, the Plan is not focused
24 on improving system average reliability indices. However, the Plan does select projects
25 based on reliability and resiliency improvements of each specific circuit. The Plan is
26 intended to cause a step change in the reliability of each modernized circuit resulting in a
27 significantly improved customer experience.
28

29 **Q. Is the Plan designed to include flexibility over the next 5 years?**

30 A. Yes. The Plan is designed so that as the market trends evolve, technology emerges, and
31 system characteristics change, the optimization criteria, guiding principles, and investment

1 criteria for project selection will continue to evolve and accommodate necessary changes
2 through the Annual Invest Plan process. In the early years, OG&E is making foundational
3 investments that are broad-scale and touch entire circuits. As the Plan progresses, and as
4 technology emerges that allows for cost effective solutions to specific areas and locations,
5 the Company will transition to a more granular approach with targeted investments to
6 specific areas, instead of circuits, and potentially to precise locations.

7
8 **Q. How were the projects selected in the 2020 and 2021 Annual Investment Plans?**

9 A. The projects in the 2020 and 2021 Annual Investment Plans were selected through the
10 following methodology. First, each distinct work activity within the list of potential
11 investments was reviewed to determine if it fit within the guiding principles for the year
12 and the associated technology was mature enough to gain the desired value for each
13 activity.

14 Second, investment criteria were developed for each distinct work activity that was
15 selected for the Annual Investment Plan. As part of the investment criteria, it was
16 determined that all line and substation distinct work activities would be limited to only
17 include work on the top 250 circuits and their associated substations when ranked by
18 criticality and condition. Criticality was determined using a mix of total circuit load and
19 customers per mile. Condition analysis included asset age, interruption counts (momentary
20 and sustained), SAIDI (system average interruption duration index), and CAIDI (customer
21 average interruption duration index). The criticality component factors in how many
22 customers/load will be affected by outages. The condition component factors in circuit
23 health by evaluating both existing reliability and aging infrastructure on each circuit.

24 Third, the net present value (including limited economic harm benefits derived
25 from the DOE's ICE calculator) of each project was used as the optimization criteria to
26 select which circuits and substations were included in the Annual Investment Plan.

III. Cost Benefit Analysis and Plan Composition

Q. Do certain responsive witnesses challenge the Plan with regard to the cost benefit analysis and project selection?

A. Yes. As I will more fully discuss below, intervenors challenged our cost benefit analysis and project selection by criticizing our decisions to:

- (a) exclude certain revenue requirement components from an optimization model not intended to calculate customer impacts,
- (b) evaluate our plan on a comprehensive circuit by circuit basis rather than project by project;
- (c) assume performance projections based on actual Arkansas Grid Enhancement results;
- (d) consider the economic and societal impacts imposed on customers during an outage and calculate a corresponding value through a DOE developed model; and,
- (e) exclude short-term answers in favor of long-term solutions.

Q. Do you agree with those criticisms?

A. No, I do not. While I acknowledge there are different ways to design a grid enhancement program and perform an associated cost benefit analysis, I firmly believe we utilized a reasonable and sound approach. Our Plan was developed by experienced engineers who performed exhaustive research and study of our system to determine how to best solve for its needs now and in the future.

Q. Before addressing the intervenors' concerns, please provide a simple explanation for how the cost-benefit analysis works.

A. The cost benefit analysis compares the costs of the various projects to the avoided cost of service and avoided economic harm benefits. The avoided cost of service benefits are based on a 60% reliability improvement and the three-year historical average number of incidents per circuit along with the following system-wide assumptions: average cost of an operations and maintenance truck roll, average cost of a capital work order, average

1 operations and maintenance storm cost, and average capital storm cost. The avoided
2 economic harm benefits are derived by leveraging the DOE's ICE calculator.

3
4 **A. Net Present Value Performed for Project Optimization**

5
6 **Q. Please describe why the cost benefit analysis was performed and how the Net Present**
7 **Value (NPV) calculation is used.**

8 A. The cost benefit analysis was developed to evaluate the costs and benefits associated with
9 each Annual Investment Plan as well as the overall benefits of the five-year plan. The NPV
10 calculation in the cost benefit model was developed for optimization of the work to ensure
11 we are investing in the most beneficial locations. It is intended to help optimize the
12 locations in which we should enhance the grid first and the volume of investments for each
13 location. The benefits in the NPV calculation are reduced for optimization purposes. This
14 in no way means the Company is discounting the benefits for each project. The benefits
15 are only limited to optimize projects with a higher value given to the cost of service benefits
16 as compared to the economic harm benefits. The Company recognizes all these benefits
17 and uses them to justify each project.

18
19 **Q. Witness Betchan testifies the Company's NPV calculation lacks all the inputs**
20 **considered in a full revenue requirement analysis.¹ Was a full revenue requirement**
21 **included in the cost benefit analysis?²**

22 A. No. OG&E used a cashflow NPV in the cost benefit analysis. It was not developed to
23 determine the customer rate impact of each project. Instead, it was developed to compare
24 circuits and substations so that work could be optimized to ensure we are investing in
25 locations with the most benefit to customers first. While the NPV calculation is a cash flow
26 analysis and not a revenue requirement impact, it does include the following: total capital
27 investment, avoided operations and maintenance expense, avoided capital investment,
28 interest expense, income tax, depreciation expense, ad valorem tax expense, and deferred

¹ Responsive Testimony of Betchan p. 24-28.

² Responsive testimony of Bohrmann p. 17.

1 tax benefit. OG&E calculated a customer impact through the revenue requirement model
2 shared in the Direct Testimony of Witness Rowlett.

3
4 **B. Comprehensive Circuit-by-Circuit Evaluation**

5
6 **Q. Witness Betchan was also critical of OG&E for not evaluating each project on a**
7 **technology-by-technology basis through the cost benefit analysis. Please explain why**
8 **OG&E did not perform its analysis in this manner.**

9 A. The paradigm of evaluating discrete costs and benefits on a project-by-project or
10 technology-by-technology basis may not lead to investments that achieve the objectives of
11 the Plan. A cost-benefit analysis on an individual project or technology is most meaningful
12 when investments have benefits and costs that are discrete and clearly attributable to the
13 individual investment. The Grid Enhancement investment types often support multiple
14 objectives and typically have joint benefits that will often increase as more capabilities and
15 functions are added. For example, replacing aging infrastructure and adding automated
16 switches to a circuit will provide a higher level of reliability than if you just did one without
17 other. For these reasons, it is not reasonable to conduct a cost benefit analysis on a
18 technology by technology basis for the Grid Enhancement Plan.

19
20 **Q. If OG&E did not evaluate work at a project level, how can it be sure that the right**
21 **projects are selected prior to being modeled at the circuit level?**

22 A. OG&E used investment criteria to evaluate each distinct work activity for each specific
23 circuit or substation prior to evaluating circuits and substations in the cost benefit model.
24 Investment criteria is determined for each distinct work activity (or technology) to ensure
25 the work activity not only meets the guiding principles for each Annual Investment Plan
26 but also yields the expected benefits. For example, on underground cable replacement, this
27 work activity is only applied to circuits with a high volume of outages caused by cable
28 failures. If there are minimal outages associated with underground cable, the work activity
29 is not applied to the circuit. Another example is transformer load management (TLM).
30 TLM is only applied to transformers with greater than 60 hours of overloading a year. In
31 another example, it was determined that costs for adding communications to capacitors was

1 running higher than expected, so this distinct work activity was removed from the 2021
2 Annual–Investment Plan. Using the investment criteria to select which distinct work
3 activities (or technology) are applied to each circuit allows OG&E to optimize the
4 investment on each circuit prior to ranking the circuits once they are analyzed by the cost
5 benefit model and ensures the most beneficial projects are selected.
6

7 **Q. In your experience, is the overall granularity of the cost benefit analysis reasonable**
8 **at the circuit-by-circuit level?**

9 A. Yes, the granularity of the analysis is reasonable. The Grid Enhancement Plan is intended
10 to cause a step change in the reliability of each circuit within the plan. In order to create
11 this step change, we needed to change our “typical” reliability and asset management
12 planning practices which evaluate programs individually and translate that into evaluating
13 which programs need to be applied to which specific circuits or substations.


14 “Typical” reliability and asset management planning practices look at a series of
15 programs to maintain “status quo” reliability levels. For example, the underground cable
16 replacement program targets the worst of the worst pieces of underground cable to replace.
17 Which means there may be pieces of conductor on several different circuits. Another
18 program for example, the transformer load management program targets the worst of the
19 worst overloaded distribution transformers to replace. Which again means transformers
20 will be replaced one at a time across the service territory without consideration of location.
21 These investments are usually not coordinated together because the intent is to maintain
22 reliability levels and replace assets just before failure.

23 The Plan, however, looks at each circuit and substation and reviews all of the
24 investment opportunities that have been identified for each year and determines the optimal
25 set of investments for each circuit and substation through the investment criteria developed
26 for each distinct work activity. Planning the investments in this manner has proven to
27 provide a “step change” in the reliability of each circuit delivering a much-improved
28 customer experience.

C. Reliability Projects Based on Actual Experience

Q. Certain responsive parties challenged the 60% reliability improvement assumption claiming it is too high. Is the 60% reliability improvement assumption reasonable?³

A. Yes, a 60% reliability improvement assumption is reasonable. Arkansas Series 1 circuits experienced a 70% improvement from the historical 3-year average in 2019 and in 2020 (year to date) has experienced 96% improvement from the historical 3-year average as shown in the chart below. Based on these *actual* experiences, the 60% reliability improvement assumption is reasonable. Witness Givens also states that PUD believes that OG&E's 60% reduction estimate may be reasonable.⁴



³ Responsive Testimonies of Alvarez p. 6 and 8; Betchan p.18; Alexander p. 12.

⁴ Responsive Testimony of Givens p. 14, Ins. 14-18.

1 Q. **Some of the same parties criticized your analysis for not considering any variability**
2 **in the reliability projection. Has a sensitivity analysis been performed on the 60%**
3 **improvement assumption?**⁵

4 A. Yes, in response to data request AG 7-16, the Company provided NPV results for each
5 substation/circuit(s) project in the 2020 Investment Plan run at 60%, 55%, 50%, 40%, and
6 30% improvements. At both 60% and 55% improvement levels, all 30 (100%) of the
7 projects are positive NPV. At 50% improvement levels, 28 (93%) of the projects are
8 positive NPV. At 40% improvement levels, 27 (90%) of the projects are at positive NPV
9 levels. And at 30% improvement levels, 23 (77%) of the projects are at positive NPV levels.

10
11 Q. **Witness Alvarez states only 52% of outage minutes resulted from equipment**
12 **deterioration and it is impossible for a 60% improvement to be secured.**⁶ **Do you agree**
13 **with his assessment?**

14 A. No. Aging infrastructure is only one component of the Grid Enhancement Plan. The Grid
15 Enhancement Plan is also adding automation to the circuits that are being modernized.
16 When you combine the benefits of automation and the fact that over half of the outage
17 duration is equipment deterioration, as Witness Alvarez points out, it is very possible to
18 achieve a 60% improvement.

19
20 Q. **Witness Alvarez also suggests that after the upgrades, SAIDI only improved 24%**
21 **relative to historical averages with storms for Arkansas Series 1 circuits.**⁷ **Is he**
22 **correct?**

23 A. No. Witness Alvarez manipulated the data by removing the year 2016 because it was a
24 high storm year. Not only is this misleading, it also is not an accurate view of a 3-year
25 historical average. The actual 3-year historical average for those circuits is 636 minutes of
26 SAIDI. The 2019 performance of those circuits was 190.5 minutes of SAIDI resulting in a
27 70% improvement over the 3-year historical average.

⁵ Responsive Testimony of Betchan p. 14.

⁶ Responsive Testimony of Alvarez p. 8, ln. 17 – p. 9, ln. 5.

⁷ *Id.* P. 8, lns. 5-10.

1 Q. **Witness Alexander suggests that OG&E double counted storm improvements by**
2 **using an 88% improvement instead of 60%.⁸ Do you agree?**

3 A. No, we did not double count storm improvements, although it is correct that 88% was
4 utilized in the storm benefit analysis. To develop the storm benefit, we reduce the possible
5 storm related costs for any particular circuit by the percent improvement of customer
6 minutes of interruption (“CMI”). To get the percent improvement of CMI, we first reduced
7 the storm related outages by applying a 60% improvement. Then, we applied a
8 normalization factor to the remaining storm related CMI per outage. The normalization
9 factor was developed using the results from our System Hardening Program where rates of
10 pole failures during storms was reviewed for both system hardened circuits and non-system
11 hardened circuits. The normalization factor is 2.23, meaning non-system hardened circuits
12 have 2.23 times more pole failures than system-hardened circuits during storms. When you
13 apply this normalization factor to the CMI per outage during a storm and multiply by the
14 60% improvement in number of outages, there is an 88% improvement to CMI during
15 storms.

16
17 **D. Full Valuation of Avoided Outages on Customers**

18
19 Q. **Certain parties such as OIEC and AARP challenge OG&E’s consideration of avoided**
20 **economic harm benefits. They claim they should not be considered if they are not**
21 **directly reflected on customers’ electric bills.⁹ Do you agree with this assertion?**

22 A. Absolutely not. It is irresponsible to ignore the total effect of outages on our customers.
23 Although outage costs on the utility’s side of the meter are easier to calculate, that doesn’t
24 excuse ignoring the costs imposed on customers on their side of the meter. Moreover, the
25 avoided economic harm benefits associated with the Plan are derived using a reputable
26 model developed by the Department of Energy--a model it has been using as part of its
27 mission to support modernization of the electric system. It begs the question as to why
28 intervenors are so quick to disregard a model supported and developed by the DOE.

⁸ Responsive Testimony of Alexander p. 14.

⁹ Responsive Testimonies of Alvarez p. 10, ln. 3 – p. 12, ln. 11; and Norwood p. 17, lns. 7-14.

1 The objective of the Plan is to minimize the total costs of electricity service by
2 balancing the cost of investments in reliability (utility costs) against the costs that
3 customers experience as a result of unreliability associated with the investment. Excluding
4 the value avoiding customer interruption costs (avoided economic harm) in valuing the
5 benefits of the Plan makes for a most incomplete equation.
6

7 **Q. AARP witness Alvarez also alleges that the benefits to residential customers are**
8 **disproportionate with costs. Are economic harm benefits different for residential,**
9 **commercial, and industrial customers?**

10 **A.** While all customers on modernized circuits, regardless of service class, will receive the
11 same reliability benefits, some classes may monetize the benefits differently. As explained
12 below, it is very difficult to monetize the residential benefits, but it is known that residential
13 customers are impacted when outages occur. Commercial and industrial customers are able
14 to monetize the reliability improvements through avoided waste, production loss, sales
15 loss, etc. Therefore, the DOE ICE calculator can produce more estimated economic harm
16 benefits for those customers.
17

18 **Q. What does the DOE ICE calculator account for in economic harm benefits for**
19 **residential customers?**

20 **A.** Residential benefits are derived primarily on surveys related to short duration (few hours
21 or less) outages, which most of these losses are intangible and extremely difficult to cost
22 out for these customers. They do not account for longer duration outages where a
23 residential customer may lose contents of fridge and freezer, therefore these costs are not
24 captured in the DOE ICE calculator. The societal costs of outages, like those that may occur
25 for customers working or learning from home during COVID, are very difficult to capture,
26 and therefore, very underestimated. Further, individual customer costs do not include
27 downstream costs such as those that occur when a customer is unable to get products and
28 services.

1 Q. **Like the Company, Witness Bohrmann suggests that economic harm benefits should**
2 **be considered as part of the Company's cost-effectiveness analysis; however, he**
3 **recommends a different method in calculating the benefits. Please explain.**

4 A. In the Company's analysis, economic harm benefits were calculated using the DOE ICE
5 calculator for all of Oklahoma assuming all circuits were modernized. Then, the benefits
6 were allocated to each circuit based upon the ratio of three-year average number of
7 incidents for the circuit compared to the system. Mr. Bohrmann testifies that the benefits
8 should instead be allocated on a circuit by circuit basis.
9

10 Q. **Why did OG&E use an allocation method for economic harm benefits instead of**
11 **running each circuit through the DOE model as recommended by Witness**
12 **Bohrmann?**¹⁰

13 A. The DOE model currently does not accept any interface inputs such as an API. An API is
14 an interface that allows access to data between systems or applications. This would have
15 allowed OG&E to load all the circuit data, send it to the DOE model and get the results for
16 all the circuits. Since the model does not accept this type of interface, OG&E attempted
17 with two different methods to automatically run each circuit through the DOE model using
18 robot technology and computer automation. Each of those methods aborted multiple times
19 and crashed the DOE model site. After each attempt, OG&E personnel contacted the DOE
20 to restart their services so that access to the model could be regained. At this point, it was
21 decided to run the model for all of Oklahoma and allocate the benefits to each circuit.
22

23 Q. **Aside from the technical issues, is the Company's allocation method for economic**
24 **harm benefits reasonable?**

25 A. Yes, the method of allocation for economic harm benefits is reasonable for the following
26 reasons. First, OG&E utilized conservative assumptions for the ICE calculator benefits
27 since these benefits are on the customer side of the meter. The total Oklahoma ICE
28 calculator was only run for 40% improvement and 20-year NPV to be conservative on the
29 customer benefit. Second, less than 20% of the total expected \$1.4 billion economic harm

¹⁰ Responsive Testimony of Bohrmann p. 21-23.

benefits is required to offset the forecasted spend of \$810.2 million when you consider the estimated \$500 million of avoided cost of service benefits. Third, only a small portion of the ICE calculator benefit is expected to be utilized when evaluating circuits within each annual investment plan. For example, the 2020 Investment Plan utilized 0% of the economic harm benefits and the 2021 Investment Plan utilized 10% of the economic harm benefits.

Q. Witness Givens questions certain assumptions used in the economic harm benefits. More specifically, he questions what the total economic harm benefits would be with assumptions of 60% improvement and 30 years?¹¹

A. If the economic harm benefit assumptions were updated to 60% improvement and 30 years, the total economic harm benefits for the Grid Enhancement Plan would be \$2.6 billion. The update would result in an increase of \$1.2 billion in customer benefit for the Plan.

Q. Witness Givens points out that the economic harm benefits were not run with the same assumptions as the cost of service benefits. What would the total economic harm (ICE calculator) benefits be for the Grid Enhancement Plan if run with the same assumptions as the Cost of Service Benefits?¹²

A. To update the economic harm (ICE calculator) benefit assumptions to match the assumptions in the cost benefit model, the following assumptions would need to be updated: (1) 60% improvement, (2) 30 year duration of benefits, (3) 2.5% reliability inflation without the projects, and (4) 2% degradation of reliability improvement after 10 years. The update would result in a total economic harm benefit for the Grid Enhancement Plan of \$3.8 billion. The update would result in an increase of \$2.4 billion in customer benefit for the Plan.

¹¹ Responsive Testimony of Givens p. 16, lns. 4-8.

¹² *Ibid.*

1 **E. Project Selection Based on Long-Term Solutions.**

2
3 Q. **Witnesses Bohrmann and Alvarez challenge the Plan's composition of projects**
4 **suggesting the Plan's objectives can be achieved with varying combinations of capital**
5 **and O&M expenses. Is this correct?**

6 A. While it is true some of the Grid Enhancement objectives could potentially be met with
7 varying combinations of capital and O&M expenses, O&M expense options such as tree
8 trimming provide only short-term benefits and need re-occurring investment to sustain the
9 benefit. The Grid Enhancement Plan is focused on providing improved experiences for
10 customers over 30 years. Therefore, it is focused specifically on capital investments, not
11 short-term solutions.

12
13 Q. **Why was additional tree trimming not included in the Grid Enhancement Plan?**

14 A. Additional tree trimming was not included because it is only aids in improving reliability
15 in the short-term. Tree trimming must be completed regularly to maintain the improved
16 reliability levels. In order to sustain the reliability benefits provided by additional tree
17 trimming, the Company must increase its cycle trimming (as discussed below).

18
19 Q. **Will tree trimming be conducted in parallel with the Grid Enhancement Plan?**

20 A. Yes. Cycle trimming established as normal course of business will continue to be
21 conducted in parallel with the Grid Enhancement Plan.


22
23 Q. **Does the Grid Enhancement Plan address tree related outages that cannot be**
24 **addressed with tree trimming alone?**

25 A. Yes, the Grid Enhancement Plan addresses tree related outages through the grid automation
26 work activities. See the figures below for an example circuit.

27
28 Example 1: If a tree limb were to fall on the line to the right of TripSaver D (represented
29 by the red X in the figure below), the TripSaver would open and reclose to clear the line
30 fault caused by the falling tree limb. If the limb fell off the line, all power would be restored
31 automatically. If the limb did not fall off the line, the TripSaver would open and crews


would be routed to the area for restoration. Only the customers in the shadow box would be affected.

Figure 1



Example 2: If a tree limb were to fall on the line between Circuit 1 Substation Breaker and Recloser A (represented by the red X in the figure below), the Circuit Breaker would open and reclose to clear the line fault caused by the falling limb. If the limb fell off the line, all power would be restored automatically. If the limb did not fall off the line, the Recloser A would open and Recloser C downstream would close allowing power to be restored to majority of the customers on the circuit. While all customers on the circuit will see a brief outage, the longer duration outage would be limited to only the customers in the shadow box below.

Figure 2



1 These two automation examples show how automated restoration can limit the exposure
2 to tree related outages and improve the outage times.

3
4 **IV. Other Issues**

5
6 **Q. Witness Alvarez also faults OG&E for not including CVR (conservation voltage**
7 **reduction) in the Grid Enhancement Plan. Did OG&E consider CVR to be included**
8 **in its Grid Enhancement Plan?¹³**

9 **A.** Yes. The Company runs voltage optimization on 400 feeders across our service territory.
10 The voltage optimization is run through an integrated volt var control (IVVC) program.
11 OG&E invested in these 400 circuits to run IVVC in both our Smart Grid and Energy
12 Efficiency Programs. When reviewed, it was determined that the remaining circuits would
13 provide diminished results. For this reason, additional IVVC was not included in the Grid
14 Enhancement Plan.

15
16 **Q. Do you agree with Witness Alvarez that spending is ill-defined because OG&E has**
17 **yet to determine how it will upgrade its communications network?¹⁴**

18 **A.** No. The communications network investment was appropriately defined for the planning
19 stage at the time. Since the filing of direct testimony, additional planning work is now
20 complete that provides increased certainty. Additionally, as detailed in the data requests
21 referenced by Witness Alvarez, the available solution options were known. Therefore, the
22 information was available at the time to generate a high-level estimate of the investment.
23 In the time since initial testimony was filed, a strategic assessment was completed,
24 analyzing the existing communication systems, industry trends, and available solutions to
25 narrow the range of solution options to be considered. That work was performed in
26 consultation with the Networks, Integration, and Automation department at Burns &
27 McDonnell, a reputable firm in the industry.

¹³ Responsive Testimony of Alvarez p. 19, Ins. 1-14.

¹⁴ *Id.* p. 23, Ins. 8-16

1 Q. **Do you agree with Witness Alvarez's example showing that \$167.5 million allocated**
2 **to distribution line reliability (from the list of potential investments) is based on a**
3 **single assumption that will be adequate for 250 circuits?**¹⁵

4 A. No. When combining the 2020 and 2021 Annual Investment Plans, 122 circuits have been
5 selected for the distribution line reliability work activity with an estimated cost of \$81
6 million. This is an average cost of \$660,000 per circuit. In the list of potential investments,
7 it was estimated for the 5-year plan that this work activity would be completed on 250
8 circuits for \$167.5 million. This would be an average of \$670,000 per circuit. Based on this
9 data, the spending forecast is on track for the distribution line reliability work activity and
10 the estimated spend is within an acceptable tolerance for forecasting accuracy.

11
12 Q. **Before concluding, please discuss whether intervenors were afforded an opportunity**
13 **to review the cost-benefit analysis model?**

14 A. Yes, however, it was not without issue. The cost benefit model was developed in the SAS
15 VA tool which is not available for use without a license. Consequently, we were initially
16 unable to provide direct access to the model other than through a virtual demonstration and
17 through a workpaper provided with my direct testimony which included a summary of the
18 model. In recognition the intervenors needed more direct access, I created an example
19 calculation in response to AG 7-11. I further provided details of the projected plan benefits
20 in response to AG 3-4 that could be used along with the spreadsheet provided in AG 7-11
21 to reproduce what was developed in the cost benefit model itself. The combination of these
22 documents enabled intervenors to recreate the model, despite the access issues created early
23 on by the SAS VA license.

24 **V. Conclusion**

25 Q. **Do you have any final remarks before concluding your testimony?**

26 A. Yes. I respectfully recommend the Commission consider the reasonableness underlying
27 the development of our five-year and recognize it was designed to yield tremendous
28 benefits to our customers as we ready our grid for the future.

¹⁵ *Ibid.*

- 1 Q. **Does this conclude your Rebuttal Testimony?**
- 2 A. Yes.